WEBER



WES 125



WES 125



$W \equiv B \equiv R$

GENERATING SET MODEL WES 125

Output Ratings	Prime
400 V,3 ph,50 Hz,1500 rpm	125 Kva
	100 kW
	Power Factor : 0.8

ENGINE / TECHNICAL DATA

Engine Make	Volvo Eicher
Engine Model	EE694TCI
Governing Type	Mechanical
Number of Cylinders	6
Rated BHP	156
Bore and Stroke mm	100 X 120
Displacement Itrs	5.7
Electric System	12 V DC
Compression Ratio	17.5:01
Injection system	Direct
Cylinder arrangement	Inline
Nature of Aspiration	TCI

STANDARD SPECIFICATIONS

Eicher heavy duty high performance industrial type diesel engine

2. ENGINE FILTRATION SYSTEM

- Cartridge type dry air filterTwo cartridge type fuel filters
- Full flow lube oil filter

All filters have replacable elements

3. COOLING RADIATOR

Radiator and cooling fan, complete with safety guards, designed to cool the engine at high ambient temperatures(consult your dealer for deration factors)

4 FXHAUST SYSTEM

Heavy duty Industrial Exhaust Silencer

Silencer noise reduction level 15 (dB) 10.0(kPa) Maximum allowable back pressure

5. CIRCUIT BREAKER TYPE

ABB 3 pole MCCB.(4 pole is optional)

6. FUEL SYSTEM

On Generating sets upto 700kVA, the baseframe design is incorporated with an integral fuel tank with a capacity of approx. 8 hours running at full load. The tank is supplied complete with fill cap breather, fuel speed and return lines to the engine and drain plug.

7 ALTERNATOR

7.1 INSULATION SYSTEM

• Insulation : Class H

• All windings are impregnated in either a triple dip thermosetting liquid, oil and acid resisting polyester varnish or vaccum pressure impregnated with a special polyester resin.

• Heavy coat of antitracking varnish additional protection against moisture or condenasation.

7.2 AUTOMATIC VOLTAGE REGULATOR (AVR)

The fully sealed AVR maintains the voltage regulation at ±0.5%. Nominal adjustment by means of a trim pot incorporated on

the AVR.

7.3 MOTOR STARTING

An overload capacity equivalent to 300% of the full load impedance at zero power factor can be sustained for 10 sec., when AREP or PMG option is fitted.

8. MOUNTING ARRANGEMENT

8.1 BASE FRAME

The complete generating set is mounted as a whole on a heavy duty fabricated steel baseframe.

8.2 COUPLING

The engine and alternator are directly coupled by means of an SAE flange. The engine flywheel is flexibly coupled to the alternator rotor.

8.3 ANTI-VIBRATION MOUNTING PADS

Anti-vibration pads are affixed between the engine / alternator feet and the baseframe thus ensuring complete vibration isolation of the rotating assembly.

Powered by:





ENGINE / TECHNICAL DATA (continued)

50Hz & 1500rpm
Prime
4
Liquid
1526X1039X1090
580
96 @ 1 mtr
Bosch Inline
23.8
159
156
0.1

[Dimension (mm) & Weight (Kg)	Length	Width	Height	Weight
(Open	2400	1100	1528	1824
9	Soundproof	3510	1210	1970	2374

ALTERNATOR DATA

Make	Leroy Somer TAL / Stamford
Model	TAL 044H / UCI274E
No. of bearings	1
Insulation Class	Н
Total Harmonic Content	on load < 5%
Wires	6 / 12
Ingress Protection	IP23
Excitation System	Shunt / Self Excited
Winding Pitch	2/3(n°3)
AVR Model	R120 / SX460
Overspeed	2250 mn ⁻¹
Voltage Regulation	±1% / ±1.5%
Short Circuit Capacity	-
AREP & PMG Excitation System Available as options	ıl

STANDARD SPECIFICATIONS

8.4 SAFETY GUARDS

The fan and fan drive along with the battery charging alternator are safety guard protected for personnel protection.

9. FACTORY TESTS

- The generating set is load tested before dispatch.
- All protective devices control functions and site load conditions are simulated. The generator and it's systems are checked before dispatch.

10. EQUIPMENT FINISHING

All mild steel components are fully degreased and painted with powder coated paint to ensure maximum scuff resistance and durability.

11. DOCUMENTATIONS

CONTROL PANEL

Operation and Maintenance manual and circuit wiring diagrams are accompanied with the generator.

Make	Deep Sea
Model	DSF4510
The DSE4510 is an Auto Start Contro	iviodule id

for single genset applications.It includes a backlit LCD display which clearly shows the status of the engine all the times. This module can either be programmed using the front panel or by using the DSE configuration suitr PC software.

Metering and Alarm Indications:

- Generator Frequency
- Underspeed, OverspeedGenerator volts(L-L,L-N)
- Generator Current
- Engine Oil PressureEngine Coolant Temperature
- Hours Run CounterBattery Volts
- Fail to start/stop
- Emergency Stop Failed to reach loading
- voltage/frequency
- Charge failLoss of magnetic pick-up signal-Optional
- Low DC VoltageCAN diagnostics and CAN fail/error





Tel: +44 20 8144 2160 Weber Generators Ltd., Office 32, 19-21 Crawford Street, London, W1H 1PJ

Email: info@webergenerators.com Website: www.webergenerators.com