# WEBER



**WES 40** 



## **WES 40**



## $W \equiv B \equiv R$

#### **GENERATING SET MODEL WES 40**

Output Ratings	Prime
380-415 V,3 ph,50 Hz,1500 rpm	40 Kva
	32 kW
	Power Factor : 0.8

#### **ENGINE / TECHNICAL DATA**

Engine Make	Volvo Eicher
Engine Model	EE483TCI
Governing Type	Mechanical
Number of Cylinders	4
Rated BHP	52
Bore and Stroke mm	100 X 105
Displacement Itrs	3.3
Electric System	12 V DC
Compression Ratio	17:01
Injection system	Direct
Cylinder arrangement	Inline
Nature of Aspiration	TCI

#### STANDARD SPECIFICATIONS

Eicher heavy duty high performance industrial type diesel engine

#### 2. ENGINE FILTRATION SYSTEM

- Cartridge type dry air filterTwo cartridge type fuel filters
- Full flow lube oil filter

All filters have replacable elements

#### 3. COOLING RADIATOR

Radiator and cooling fan, complete with safety guards, designed to cool the engine at high ambient temperatures(consult your dealer for deration factors)

#### 4 FXHAUST SYSTEM

Heavy duty Industrial Exhaust Silencer

Silencer noise reduction level 15 (dB) 10.0(kPa) Maximum allowable back pressure

#### 5. CIRCUIT BREAKER TYPE

ABB 3 pole MCCB.(4 pole is optional)

#### 6. FUEL SYSTEM

On Generating sets upto 700kVA, the baseframe design is incorporated with an integral fuel tank with a capacity of approx. 8 hours running at full load. The tank is supplied complete with fill cap breather, fuel speed and return lines to the engine and drain plug.

#### 7 ALTERNATOR

#### 7.1 INSULATION SYSTEM

• Insulation : Class H

• All windings are impregnated in either a triple dip thermosetting liquid, oil and acid resisting polyester varnish or vaccum pressure impregnated with a special polyester resin.

• Heavy coat of antitracking varnish additional protection

7.2 AUTOMATIC VOLTAGE REGULATOR (AVR)

against moisture or condenasation.

### The fully sealed AVR maintains the voltage regulation at ±0.5%. Nominal adjustment by means of a trim pot incorporated on

the AVR.

#### 7.3 MOTOR STARTING

An overload capacity equivalent to 300% of the full load impedance at zero power factor can be sustained for 10 sec., when AREP or PMG option is fitted.

#### 8. MOUNTING ARRANGEMENT

#### 8.1 BASE FRAME

The complete generating set is mounted as a whole on a heavy duty fabricated steel baseframe.

#### 8.2 COUPLING

The engine and alternator are directly coupled by means of an SAE flange. The engine flywheel is flexibly coupled to the alternator rotor.

#### 8.3 ANTI-VIBRATION MOUNTING PADS

Anti-vibration pads are affixed between the engine / alternator feet and the baseframe thus ensuring complete vibration isolation of the rotating assembly.

#### Powered by:





#### **ENGINE / TECHNICAL DATA (continued)**

50Hz & 1500rpm
Prime
2
Liquid
1002x783x884
380
94 @ 1 mtr
Bosch Inline
11
158
164
0.1

Dimension (mm) & Weight (Kg)	Length	Width	Height	Weight	
Open	1570	800	1300	900	
Soundproof	2290	1110	1600	1300	

#### **ALTERNATOR DATA**

Make	Leroy Somer TAL / Stamford
Model	TAL 042F / UCI224D
No. of bearings	1
Insulation Class	Н
Total Harmonic Content	on load < 5%
Wires	6/12
Ingress Protection	IP23
Excitation System	Shunt / Self Excited
Winding Pitch	2/3(n°6)
AVR Model	R120 / SX460
Overspeed	2250 mn <sup>-1</sup>
Voltage Regulation	±1% / ±1.5%
Short Circuit Capacity	-
AREP & PMG Excitation System Available as optional	

#### STANDARD SPECIFICATIONS

#### 8.4 SAFETY GUARDS

The fan and fan drive along with the battery charging alternator are safety guard protected for personnel protection.

#### 9. FACTORY TESTS

- The generating set is load tested before dispatch.
- All protective devices control functions and site load conditions are simulated. The generator and it's systems are checked before dispatch.

#### 10. EQUIPMENT FINISHING

All mild steel components are fully degreased and painted with powder coated paint to ensure maximum scuff resistance and durability.

#### 11. DOCUMENTATIONS

Operation and Maintenance manual and circuit wiring diagrams are accompanied with the generator.

	CONTROL PANEL		
	Make	Deep Sea	
	Model	DSE4510	
The DSE4510 is an Auto Start Control Module for single			
	applications.It includes a backlit LCD display which clearly		
the status of the engine all the times. This module can			

set nows r be programmed using the front panel or by using the DSE configuration suitr PC software.

Metering and Alarm Indications:

- Generator Frequency
- Underspeed, OverspeedGenerator volts(L-L,L-N)
- Generator Current
- Engine Oil Pressure
  Engine Coolant Temperature
  Fuel Level
- Hours Run CounterBattery Volts
- Fail to start/stop
- Emergency Stop Failed to reach loading
- voltage/frequency
- Charge failLoss of magnetic pick-up signal-Optional
- Low DC VoltageCAN diagnostics and CAN fail/error





Tel: +44 20 8144 2160 Weber Generators Ltd., Office 32, 19-21 Crawford Street, London, W1H 1PJ

Email: info@webergenerators.com Website: www.webergenerators.com