







## **WPS100**



# WEBER

### **GENERATING SET MODEL WPS 100**

Output Ratings	Prime	Standby
400 V,3 ph,50 Hz,1500 rpm	100 kVA	110 kVA
	80 kW	88 kW
480 V,3 ph,60 Hz,1800 rpm	112 kVA	125 kVA
	89.6 kW	100 kW
		Power Factor : 0.8

## **ENGINE / TECHNICAL DATA**

Engine Make	Perkins
Engine Model	1104C-44TAG2
Governing Type	Electronic
Number of Cylinders	4
Cylinder Arrangement	Vertical In Line
Bore and Stroke mm	105x127
Displacement / Cubic Capacity Itrs	4.41
Induction System	Turbocharged, air to air
Cycle	4 stroke
Combustion System	Direct Injection
Compression Ratio	18.2:1
Rotation	Anti-clockwise
Cooling System	Water Cooled

#### STANDARD SPECIFICATIONS

1.

Perkins four stroke heavy duty high performance industrial type diesel engine

#### 2. ENGINE FILTRATION SYSTEM

- Cartridge type dry airfilter
- Two cartridge type fuelfilters
- Full flow lube oilfilter All filters have replacable elements

#### 3. COOLINGRADIATOR

Radiator and cooling fan, complete with safety guards, designed to cool the engine at high ambient temperatures(consult your dealer for deration factors)

#### 4. EXHAUSTSYSTEM

Heavy duty Industrial Exhaust Silencer

Silencer noisereductionlevel 13 (dB) 18.0(kPa) @ 50Hz Maximum allowablebackpressure

5. CIRCUIT BREAKERTYPE ABB 3 pole MCCB.(4 pole is optional)

#### 6. FUELSYSTEM

On Generating sets upto 700kVA, the baseframe design is incorporated with an integral fuel tank with a capacity of approx. 8 hours running at full load. The tank is supplied complete with fill cap breather, fuel speed and return lines to the engine and drain plug.

#### 7. ALTERNATOR

- 7.1 INSULATIONSYSTEM

Insulation : ClassHAll windings are impregnated in either a triple dip thermosetting liquid, oil and acid resisting polyester varnishorvaccumpressure impregnated with a special polyester resin. Heavycoatofantitrackingvarnishadditionalprotection against moisture orcondenasation.

#### 7.2 AUTOMATIC VOLTAGE REGULATOR(AVR)

The fully sealed AVR maintains the voltage regulation at  $\pm 0.5\%$ . Nominal adjustment by means of a trim pot incorporated on the AVR.

#### 7.3 MOTORSTARTING

An overload capacity equivalent to 300% of the full load impedanceatzeropowerfactorcanbesustainedfor10 sec., when AREP or PMG option isfitted.

#### 8. MOUNTINGARRANGEMENT

8.1 BASEFRAME The complete generating set is mounted as a whole on a heavy duty fabricated steel baseframe.

#### 8.2 COUPLING

The engine and alternator are directly coupled by means of an SAE flange. The engine flywheel is flexibly coupled to the alternator rotor.

#### 8.3 ANTI-VIBRATION MOUNTING PADS

Anti-vibration pads are affixed between the engine / alternator feet and the baseframe thus ensuring complete vibration isolation of the rotating assembly.



### **ENGINE / TECHNICAL DATA (continued)**

Frequency and Engine Speed	50Hz & 1500rpm		60Hz & 1800rpm	
	Prime	Standby	Prime	Standby
Gross Engine Power kW(hp)	93.6(125.5)	103(138)	106.8(143.2)	117.5(157.5)
Fuel Consumption @50%load L/hr	11.2	-	14.1	-
@75%load L/hr	17.1	-	20.2	-
@100%load L/hr	22.6	24.9	26.9	29.7
Total Lubrication System Capacity Itrs	8	8	8	8
Total Coolant Capacity Itrs	12.6	12.6	12.6	12.6
Exhaust Temperature °C	514	543	517	574
Radiator Cooling Air Flow(Min):m <sup>3</sup> /sec	2.76	2.76	3.76	3.76
Combustion Air Flow:m <sup>3</sup> /min	6.01	6.27	7.75	7.8
Exhaust Gas Flow:m <sup>3</sup> /min	15.2	16.3	18.4	20.4
Fuel Tank Capacity: Itrs	182	182	182	182
Dimension (mm) & Weight (Kg) Length	Width Height	Weight		

	0 ( 0)	0		0	0
Open		1980	900	1350	1150
Soundproof		2800	1110	1770	1690

## **ALTERNATOR DATA**

Make	Leroy Somer TAL / Stamford
Model	TAL 044D / UCI274C
No. of bearings	1
Insulation Class	Н
Total Harmonic Content	on load < 5%
Wires	6 / 12
Ingress Protection	IP23
Excitation System	Shunt / Self Excited
Winding Pitch	2/3(n°3)
AVR Model	R120 / SX460
Overspeed	2250 mn <sup>-1</sup>
Voltage Regulation	±1% / ±1.5%

AREP & PMG Excitation System Available as optional

#### STANDARD SPECIFICATIONS

**84 SAFETYGUARDS** The fan and fan drive along with the battery charging alternator are safety guard protected for personnel protection.

#### 9. FACTORYTESTS

• The generating set is load tested beforedispatch.

 All protective devices control functions and site load conditionsaresimulated. Thegeneratorandit'ssystemsare checked beforedispatch.

#### 10. EQUIPMENTFINISHING

All mild steel components are fully degreased and painted with powder coated paint to ensure maximum scuff resistance and durability.

#### 11. DOCUMENTATIONS

Operation and Maintenance manual, circuit wiring diagrams and commissioning/fault finding instruction leaflets are accompanied with the generator.

#### CONTROL PANEL Make Deep Sea

Model DSE4510 The DSE4510 is an Auto Start Control Module for single genset applications. It includes a backlitLCD display which clearly shows the status of the engine all the times. This module can either be programmed using the front panel or by using the DSE configuration suitr PCsoftware.

Metering and AlarmIndications:

- GeneratorFrequency
- Underspeed, Overspeed
   Generatorvolts(L-L,L-N)
- GeneratorCurrent
- Engine OilPressureEngine CoolantTemperature
- FuelLevel
- Hours RunCounter
  BatteryVolts
- Fail tostart/stop

EmergencyStop
 Failed to reachloading

- voltage/frequency Chargefail
   Loss of magneticpick-up
- - signal-Optional
  - Low DCVoltageCAN diagnostics and CAN fail/error



## WEBER

Tel: +44 20 8144 2160 Weber Generators Ltd., Office 32, 19-21 Crawford Street, London, W1H 1PJ

Email: info@webergenerators.com Website: www.webergenerators.com