WEBER







WPS 200



WEBER

GENERATING SET MODEL WPS 200

Output Ratings	Prime	Standby
400 V,3 ph,50 Hz,1500 rpm	200 kVA	220 kVA
	160 kW	176 kW
		Power Factor : 0.8

ENGINE / TECHNICAL DATA

Engine Make	Perkins	
Engine Model	1106A-70TAG4	
Governing Type	Mechanical	
Number of Cylinders	6	
Cylinder Arrangement	Vertical In Line	
Bore and Stroke mm	105x135	
Displacement / Cubic Capacity Itrs	7.01	
Induction System	Turbocharged, air to air	
Cycle	4 stroke	
Combustion System	Direct Injection	
Compression Ratio	16:1	
Rotation	Anti-clockwise	
Cooling System	Water Cooled	

STANDARD SPECIFICATIONS

1. ENGINE

Perkins four stroke heavy duty high performance industrial type diesel engine

2. ENGINE FILTRATION SYSTEM

- Cartridge type dry air filterTwo cartridge type fuel filters
- Full flow lube oil filter

All filters have replacable elements

3. COOLING RADIATOR

Radiator and cooling fan, complete with safety guards, designed to cool the engine at high ambient temperatures (consult your dealer for deration factors)

4. EXHAUST SYSTEM

Heavy duty Industrial Exhaust Silencer

Silencer noise reduction level 12 (dB) Maximum allowable back pressure 6.0(kPa) @ 50 Hz

5. CIRCUIT BREAKER TYPE

ABB 3 pole MCCB.(4 pole is optional)

6. FUEL SYSTEM

On Generating sets upto 700kVA, the baseframe design is incorporated with an integral fuel tank with a capacity of approx. 8 hours running at full load. The tank is supplied complete with fill cap breather, fuel speed and return lines to the engine and drain plug.

7. ALTERNATOR

7.1 INSULATION SYSTEM

- Insulation : Class H
- All windings are impregnated in either a triple dip thermosetting liquid, oil and acid resisting polyester varnish or $vaccum\ pressure\ impregnated\ with\ a\ special\ polyester\ resin.$
- Heavy coat of antitracking varnish additional protection against moisture or condenasation.

7.2 AUTOMATIC VOLTAGE REGULATOR (AVR)

The fully sealed AVR maintains the voltage regulation at ±0.5%. Nominal adjustment by means of a trim pot incorporated on the AVR.

7.3 MOTOR STARTING

An overload capacity equivalent to 300% of the full load impedance at zero power factor can be sustained for 10 sec., when AREP or PMG option is fitted.

8. MOUNTING ARRANGEMENT

8.1 BASE FRAME

The complete generating set is mounted as a whole on a heavy duty fabricated steel baseframe.

8.2 COUPLING

The engine and alternator are directly coupled by means of an SAE flange. The engine flywheel is flexibly coupled to the alternator rotor.

8.3 ANTI-VIBRATION MOUNTING PADS

Anti-vibration pads are affixed between the engine / alternator $% \left(1\right) =\left(1\right) \left(1\right) \left($ feet and the baseframe thus ensuring complete vibration isolation of the rotating assembly.



ENGINE / TECHNICAL DATA (continued)

Frequency and Engine Spe	ed	50Hz & 1500rpm	
	Prime	S	tandby
Gross Engine Power Kw(hp	178.9(240)	196.3(263)
Fuel Consumption @509	6load L/hr 23.1		-
@75%	Sload L/hr 34.7		-
@100	%load L/hr 45.8		49.4
Total Lubrication System Ca	apacity ltrs 16.5		16.5
Total Coolant Capacity Itrs	21		21
Exhaust Temperature °C	550		550
Radiator Cooling Air Flow(N	/lin):m³/sec 4.7		4.7
Combustion Air Flow:m³/m	in 12.6		13.2
Exhaust Gas Flow:m³/min	34.9		36.8
Fuel Tank Capacity: Itrs	367		367

Dimension (mm) & Weight (Kg)	Length	Width	Height	Weight
Open	2400	1100	1528	1980
Soundproof	3510	1210	1970	2470

ALTERNATOR DATA

Make	Leroy Somer TAL / Stamford	
Model	TAL 046B / UCI274H	
No. of bearings	1	
Insulation Class	Н	
Total Harmonic Content	On load <3.5% / <5%	
Wires	6 / 12	
Ingress Protection	IP23	
Excitation System	Shunt / Self Excited	
Winding Pitch	2/3(n°6)	
AVR Model	R150 / SX460	
Overspeed	2250 mn ⁻¹	
Voltage Regulation	±1% / ±1.5%	
Short Circuit Capacity	-	
AREP & PMG Excitation System Available as optional		

STANDARD SPECIFICATIONS

8.4 SAFETY GUARDSThe fan and fan drive along with the battery charging alternator are safety guard protected for personnel protection.

9. FACTORY TESTS

- The generating set is load tested before dispatch.
- All protective devices control functions and site load conditions are simulated. The generator and it's systems are checked before dispatch.

10. EQUIPMENT FINISHING

All mild steel components are fully degreased and painted with powder coated paint to ensure maximum scuff resistance and durability.

11. DOCUMENTATIONS

Operation and Maintenance manual, circuit wiring diagrams and commissioning/fault finding instruction leaflets are accompanied with the generator.

CONTROL PANEL

Deep Sea DSE4510

The DSE4510 is an Auto Start Control Module for single genset applications. It includes a backlit LCD display which clearly shows the status of the engine all the times. This module can either be programmed using the front panel or by using the DSE configuration suitr PC software.

Metering and Alarm Indications:

- Generator Frequency
- Underspeed, Overspeed
 Generator volts(L-L,L-N)
- Generator Current
- Engine Oil Pressure Engine Coolant Temperature
- Fuel Level
- Hours Run CounterBattery Volts
- Fail to start/stop
- Emergency Stop Failed to reach loading
- voltage/frequency
- Charge fail
 Loss of magnetic pick-up signal-Optional
- Low DC Voltage
 CAN diagnostics and CAN fail/error





Tel: +44 20 8144 2160 Weber Generators Ltd., Office 32, 19-21 Crawford Street, London, W1H 1PJ

Email: info@webergenerators.com Website: www.webergenerators.com