# WEBER



WVS 350



# **WVS 350**



# WEBER

# **GENERATING SET MODEL WVS 350**

Output Ratings	Prime	Standby
400 V,3 ph,50 Hz,1500 rpm	352 kVA	387 kVA
	282 kW	310 kW
480 V,3 ph,60 Hz,1800 rpm	401 kVA	438 kVA
	321 kW	351 kW
		Power Factor : 0.8

# **ENGINE / TECHNICAL DATA**

Engine Make	Volvo Penta
Engine Model	TAD1342GE
Governing Type	Electronic
Number of Cylinders	6
Cylinder Arrangement	Vertical In Line
Bore and Stroke mm	131x158
Displacement / Cubic Capacity Itrs	12.78
Aspiration	Turbocharged
Cycle	4 stroke
Combustion System	Direct Injection
Compression Ratio	18.1:1

#### STANDARD SPECIFICATIONS

1.

Volvo four stroke heavy duty high performance industrial type diesel engine

#### 2. ENGINE FILTRATION SYSTEM

- Cartridge type dry air filter
- Two cartridge type fuel filters
- Full flow lube oil filter

All filters have replacable elements

#### 3. COOLING RADIATOR

Radiator and cooling fan, complete with safety guards, designed to cool the engine at high ambient temperatures (consult your dealer for deration factors)

# 4. EXHAUST SYSTEM

Heavy duty Industrial Exhaust Silencer

Silencer noise reduction level 14 (dB) Maximum allowable back pressure 10.0(kPa)

#### 5. CIRCUIT BREAKER TYPE

ABB 3 pole MCCB.(4 pole is optional)

# 6. FUEL SYSTEM

On Generating sets upto 700kVA, the baseframe design is incorporated with an integral fuel tank with a capacity of approx. 8 hours running at full load. The tank is supplied complete with fill cap breather, fuel speed and return lines to the engine and drain plug.

# 7. ALTERNATOR

#### 7.1 INSULATION SYSTEM

• Insulation : Class H

• All windings are impregnated in either a triple dip thermosetting liquid, oil and acid resisting polyester varnish or vaccum pressure impregnated with a special polyester resin.

Heavy coat of antitracking varnish additional protection against moisture or condenasation.

# 7.2 AUTOMATIC VOLTAGE REGULATOR (AVR)

The fully sealed AVR maintains the voltage regulation at ±0.5%. Nominal adjustment by means of a trim pot incorporated on the AVR.

### 7.3 MOTOR STARTING

An overload capacity equivalent to 300% of the full load impedance at zero power factor can be sustained for 10 sec., when AREP or PMG option is fitted.

# 8. MOUNTING ARRANGEMENT

# 8.1 BASE FRAME

The complete generating set is mounted as a whole on a heavy duty fabricated steel baseframe.

#### 8.2 COUPLING

The engine and alternator are directly coupled by means of an SAE flange. The engine flywheel is flexibly coupled to the alternator rotor.

#### 8.3 ANTI-VIBRATION MOUNTING PADS

Anti-vibration pads are affixed between the engine / alternator feet and the baseframe thus ensuring complete vibration isolation of the rotating assembly.

# Powered by:





# **ENGINE / TECHNICAL DATA (continued)**

Frequency and Engine Speed		50Hz & 1500rpm	60Hz & 1800rpm
		Prime	Prime
Gross Engine Power	rkWm	303	345
Fuel Consumption	@50%load I/hr	36.25	42.5
	@75%load I/hr	52.21	61.6
	@100%load l/hr	68.89	82.55
Oil Consumption (I/	hr)	0.04	0.05
Oil Sump Capacity, I		30	30
Heat Rejection at Ex	khaust (Standby) kW	213	287
Exhaust Temperatu	re °C Standby	408	481
Radiator Cooling Air	r Flow : m³/s	6.7	8.2
Combustion Air Flov	w (Standby) : m³/min	25.9	28.7
Exhaust Gas Flow (S	Standby) : m³/min	57	69.5

Dimension (mm) & Weight (Kg)	Length	Width	Height	Weight
Open	3800	1130	2155	3470
Soundproof	4400	1710	2570	4887

# **ALTERNATOR DATA**

Make	Leroy Somer TAL / Stamford
Model	TAL 046H / HCI444E
No. of bearings	1
Insulation Class	Н
Total Harmonic Content	On load <5%
Wires	6 / 12
Ingress Protection	IP23
Excitation System	Shunt / Self Excited
Winding Pitch	2/3(n°6)
AVR Model	R120 / SX440
Overspeed	2250 mn <sup>-1</sup>
Voltage Regulation	±1%
Short Circuit Capacity	-
AREP & PMG Excitation System Available as optional	

#### STANDARD SPECIFICATIONS

#### 8.4 SAFETY GUARDS

The fan and fan drive along with the battery charging alternator are safety guard protected for personnel protection.

# 9. FACTORY TESTS

- The generating set is load tested before dispatch.
- All protective devices control functions and site load conditions are simulated. The generator and it's systems are checked before dispatch.

#### 10. EQUIPMENT FINISHING

All mild steel components are fully degreased and painted with powder coated paint to ensure maximum scuff resistance and durability.

#### 11. DOCUMENTATIONS

Operation and Maintenance manual, circuit wiring diagrams and commissioning/fault finding instruction leaflets are accompanied with the generator

# CONTROL PANEL

DSE4510

The DSE4510 is an Auto Start Control Module for single genset applications.It includes a backlit LCD display which clearly shows the status of the engine all the times. This module can either be programmed using the front panel or by using the DSE configuration suitr PC software.

# Metering and Alarm Indications:

- Generator Frequency
- · Underspeed, Overspeed Generator volts(L-L,L-N)
- Generator CurrentEngine Oil Pressure
- Engine Coolant Temperature
- Fuel Level
   Hours Run Counter
- Battery Volts
- Fail to start/stop
- Emergency Stop
- Failed to reach loading voltage/frequency
  Charge fail
  Loss of magnetic pick-up

- signal-Optional
  Low DC Voltage
  CAN diagnostics and CAN fail/error





Tel: +44 20 8144 2160 Weber Generators Ltd., Office 32, 19-21 Crawford Street, London, W1H 1PJ

Email: info@webergenerators.com Website: www.webergenerators.com